CromaFlow Model CF25

SPECIFICATIONS

The Model CF25 treatment system is constructed with a fiberglass tank, noncorrosive internal parts, PVC schedule 40 and/or schedule 80 piping, stainless steel trash screening, one (1) submersible aeration pumps with venturi system, one (1) submersible transfer pump, one (1) RAS pump, one (1) submersible discharge pumps sized to meet total dynamic head requirements of the project with floating decanter, and HMI/PLC controls with remote monitoring/operations ready controls.

| | $CROMAFLOW\ CF25$ | U.S.A customary units | Metric |
|----|--|--------------------------------------|------------------------------------|
| 1 | Tank dimensions | 14'10"L x 6'10"W x 6'10"H | 4.5 m x 2.1 m x 2.1 m |
| 2 | Rated treatment capacity | 2500~ m gpd | 9.46 m³/day |
| 3 | Total tank volume | 2716 gallons | $10.28 \; \mathrm{m}^{3}$ |
| 4 | Aeration volume | 1889 gallons | 7.15 m^3 |
| 5 | Clarifier volume | 827 gallons | 3.13 m^3 |
| 6 | Discharge volume | 420 gallons | 1.6 m^3 |
| 7 | Discharge cycles/day | 6 cycles/day | 6 cycles/day |
| 8 | Surge capacity | 1190 gallons | 4.5 m^3 |
| 9 | Aeration capability(with standard pumps) | 16.4 lbs. O ₂ /day | $7.4~{ m kg}~{ m O}_2/{ m day}$ |
| 10 | Maximum organic loading | 6 lbs. BOD5/day | 2.7 kg BOD₅/day |
| 11 | ${\rm Design\ influent\ BOD_5}$ | $340~\mathrm{mg/L}$ | $340~\mathrm{mg/L}$ |
| 12 | Design influent TSS | $340~\mathrm{mg/L}$ | $340~\mathrm{mg/L}$ |
| 13 | Design influent nitrogen (Ammonia) | $35 \mathrm{\ mg/L}$ | $35~\mathrm{mg/L}$ |
| 14 | Design influent TKN | $55~\mathrm{mg/L}$ | $55~\mathrm{mg/L}$ |
| 15 | Effluent CBOD (Carbonaceous) | <u>≤</u> 25 mg/L | <u>≤</u> 25 mg/L |
| 16 | Effluent TSS | <u>≤</u> 25mg/L | <u>≤</u> 25 mg/L |
| 17 | Effluent TN | ≤10 mg/L (Running denitrification) | ≤10 mg/L (Running denitrification) |
| 18 | Effluent TKN | ≤20 mg/L (with nitrification) | ≤20 mg/L(with nitrification) |
| 15 | Standard aerator efficiency (SAE) | 0.81 lbs. O ₂ /hp-hr. | 0.37 kg O ₂ /hp-hr. |
| 16 | Oxygen transfer rate (OTR) | $0.40~\mathrm{lbs.}~\mathrm{O_2/hr}$ | $0.18~{ m kg}~{ m O}_2/{ m hr}$ |
| 17 | Minimum design dissolved oxygen (DURING AERATION AT ≤DESIGN MLVSS) | 2.0 mg/L | 2.0 mg/L |
| 18 | Retention time | 12-50 hours | 12-50 hours |

Power: Per site requirements. Electrical is designed project specific 50 or 60 Hz.

Control panel: HMI/PLC controls with NEMA 4x enclosure standard, NEMA 3-13 available as an option.

Alarm System: Red, yellow, green stack light.

Tank construction materials: molded chopped strand fiberglass reinforced using isophthalic polyester resin and finished with marine grade gel coat.

Aeration equipment: Differential pressure injectors (venturi system) in combination with submersible pumps.