

CromaFlow Model CF30 SPECIFICATIONS

The Model CF30 treatment system is constructed with a fiberglass tank, noncorrosive internal parts, PVC schedule 40 and/or schedule 80 piping, stainless steel trash screening, two (2) submersible aeration pumps with venturi system, one (1) submersible transfer pump, one (1) RAS pump, two (2) submersible discharge pumps sized to meet total dynamic head requirements of the project with floating decanter, and HMI/PLC controls with remote monitoring/operations ready controls.

	<i>CROMAFLOW CF30</i>	<i>U.S.A customary units</i>	<i>Metric</i>
1	Tank dimensions	14'10"L x 6'10"W x 6'10"H	4.5m x 2.1m x 2.1m
2	Rated treatment capacity	3000 gpd	9.5 m ³ /day
3	Total tank volume	2915 gallons	11.03 m ³
4	Aeration volume	1950 gallons	7.38 m ³
5	Clarifier volume	835gallons	3.16 m ³
6	Discharge volume	375 gallons	1.6 m ³
7	Discharge cycles/day	8 cycles/day	8 cycles/day
8	Surge capacity	1189 gallons	4.5 m ³
9	Aeration capability(with standard pumps)	24.3 lbs. O ₂ /day	7.4 kg O ₂ /day
10	Maximum organic loading	7.6 lbs. BOD ₅ /day	3.4 kg BOD ₅ /day
11	Design influent BOD ₅	340 mg/L	340 mg/L
12	Design influent TSS	340 mg/L	340 mg/L
13	Design influent nitrogen (Ammonia)	35 mg/L	35 mg/L
14	Design influent TKN	55 mg/L	55 mg/L
15	Effluent CBOD (Carbonaceous)	≤25 mg/L	≤25 mg/L
16	Effluent TSS	≤25mg/L	≤25 mg/L
17	Effluent TN	≤10 mg/L (Running denitrification)	≤10 mg/L (Running denitrification)
18	Effluent TKN	≤20 mg/L (with nitrification)	≤20 mg/L (with nitrification)
15	Standard aerator efficiency (SAE)	0.81 lbs. O ₂ /hp-hr.	0.37 kg O ₂ /hp-hr.
16	Oxygen transfer rate (OTR)	0.40 lbs. O ₂ /hr	0.18 kg O ₂ /hr
17	Minimum design dissolved oxygen (DURING AERATION AT ≤DESIGN MLVSS)	2.0 mg/L	2.0 mg/L
18	Retention time	12-50 hours	12-50 hours

Power: Per site requirements. Electrical is designed project specific 50 or 60 Hz.

Control panel: HMI/PLC controls with NEMA 4x enclosure standard, NEMA 3-13 available as an option.

Alarm System: Red, yellow, green stack light with remote monitoring/operations to the internet via a dedicated IP address.

Tank construction materials: molded chopped strand fiberglass reinforced using isophthalic polyester resin and finished with marine grade gel coat.

Aeration equipment: Differential pressure injectors (venturi system) in combination with submersible pumps.